

Stormwater Quality Monitoring Data

Environmental Protection License No: 13181	Samples Collected: 15 August 2015
---	-----------------------------------

	Units	EPL Criteria	Monitoring Pit 1	Monitoring Pit 2	Monitoring Pit 3	Monitoring Pit 4
pH		6.5 – 8.5	No sample*	No sample*	No sample*	6.87
Total Nitrogen as N	mg/L	10	No sample	No sample	No sample	7.2
Oil and Grease	mg/L	10	No sample	No sample	No sample	10
Reactive Phosphorous	mg/L	*	No sample	No sample	No sample	<0.01
Total Suspended Solids	mg/L	50	No sample	No sample	No sample	34

* Samples not collected from Pits 1- 3 due to valves being closed and no stormwater discharging from site.