

Stormwater Quality Monitoring Data

Environmental Protection Licence No: 13181	Samples Collected: 05/07 July 2016
---	------------------------------------

	Units	EPL Criteria	Monitoring Pit 1	Monitoring Pit 2	Monitoring Pit 3	Monitoring Pit 4
pH		6.5 – 8.5	6.39	6.91	6.87	6.87
Total Nitrogen as N	mg/L	10	2.4	1.4	1.7	3.0
Oil and Grease	mg/L	10	<5	<5	<5	<5
Reactive Phosphorous	mg/L	*	0.035	0.045	0.014	<0.42
Total Suspended Solids	mg/L	50	35	45	18	42

*no monitoring criteria for Reactive Phosphorus parameter