

Stormwater Quality Monitoring Data

Environmental Protection Licence No: 13181	Samples Collected: 26 May 2016
---	--------------------------------

	Units	EPL Criteria	Monitoring Pit 1	Monitoring Pit 2	Monitoring Pit 3	Monitoring Pit 4
pH		6.5 – 8.5	6.9	7.15	7.10	7.38
Total Nitrogen as N	mg/L	10	0.7	0.4	0.8	9.1
Oil and Grease	mg/L	10	<5	<5	7	<5
Reactive Phosphorous	mg/L	*	0.003	0.003	0.004	0.013
Total Suspended Solids	mg/L	50	<5	<5	<5	33

*no monitoring criteria for Reactive Phosphorus parameter