

## Stormwater Quality Monitoring Data

|   |                                      |
|---|--------------------------------------|
| Environmental Protection License<br>No: 13181 | Samples Collected: 02 September 2014 |
|   | Data Received: 26 September 2014     |
|   | Date Published: 03 October 2014      |

|                              | Units | EPL<br>Criteria | Monitoring<br>Pit 1 | Monitoring<br>Pit 2 | Monitoring<br>Pit 3 | Monitoring<br>Pit 4 |
|------------------------------|-------|-----------------|---------------------|---------------------|---------------------|---------------------|
| pH                           |       | 6.5 – 8.5       | 6.18                | 6.18                | 6.24                | 6.32                |
| Total<br>Nitrogen as<br>N    | mg/L  | 10              | 1.1                 | 12.9                | 14.2                | 2                   |
| Oil and<br>Grease            | mg/L  | 10              | <5                  | <5                  | <5                  | <5                  |
| Reactive<br>Phosphorous      | mg/L  | *               | 0.01                | 0.01                | 0.01                | 0.02                |
| Total<br>Suspended<br>Solids | mg/L  | <b>50**</b>     | 11                  | 7                   | 11                  | 25                  |

\*\* Note EPL 13181 Licence Variation 10 June 2014 criteria for Total Suspended Solids (TSS) varied from 30mg/L up to 50mg/L.