

Stormwater Quality Monitoring Data

Environmental Protection License No: 13181	Samples Collected: 15 October 2014
	Data Received: 4 November 2014
	Date Published: 11 November 2014

	Units	EPL Criteria	Monitoring Pit 1**	Monitoring Pit 2**	Monitoring Pit 3**	Monitoring Pit 4
pH		6.5 – 8.5	NA	NA	NA	7.31
Total Nitrogen as N	mg/L	10	NA	NA	NA	0.5
Oil and Grease	mg/L	10	NA	NA	NA	<5
Reactive Phosphorous	mg/L	*	NA	NA	NA	0.04
Total Suspended Solids	mg/L	50	NA	NA	NA	7

** Note Due to volume of pits and total rainfall Pits 1,2 and 3 did not discharge stormwater during the month of October