

Stormwater Quality Monitoring Data

Environmental Protection Licence No: 13181	Samples Collected: 9th September 2016
---	---------------------------------------

	Units	EPL Criteria	Monitoring Pit 1**	Monitoring Pit 2**	Monitoring Pit 3**	Monitoring Pit 4
pH		6.5 – 8.5	-	-	-	7.35
Total Nitrogen as N	mg/L	10	-	-	-	1.2
Oil and Grease	mg/L	10	-	-	-	<5
Reactive Phosphorous	mg/L	*	-	-	-	<0.042
Total Suspended Solids	mg/L	50	-	-	-	33

*no monitoring criteria for Reactive Phosphorus parameter

** no sample able to be collected